



**Public Health Department**

**Environmental Health**

202 Mira Loma Drive  
Oroville, California 95965

**Camp Fire Septic System  
Inspection Report** revised 032720

T: 530.552.3880  
F: 530.538.5339

[buttecounty.net/publichealth](http://buttecounty.net/publichealth)

APN: \_\_\_\_\_ Owner Telephone: \_\_\_\_\_

Parcel Address: \_\_\_\_\_

Property Owner Name: \_\_\_\_\_

Property Owner Mailing Address: \_\_\_\_\_

Prior to inspection, contact Butte County Environmental Health for septic records. If no records are available, an As-Built of the existing tank and leach lines will be required (Form AS).

**Septic Tank Physical Observations**

Tank Material: Concrete  Fiberglass  Poly  Wood (Not Including Baffle)

Inlet T: Present: Yes  No  In Good Condition: Yes  No

Outlet T: Present: Yes  No  In Good Condition: Yes  No

Is Effluent In The Tank At Normal Operating Level? Yes  No

If Not, Explain? \_\_\_\_\_

Baffle/ Sidewalls/ Top Has Visible Cracks/Deterioration: Yes  No

If So, Explain. \_\_\_\_\_

Overall Tank Condition: Good  Fair  Poor

General Comments: \_\_\_\_\_

**Drain Field Operational Observations**

Perform Hydraulic Test of Effluent Line to Dispersal Field

Introduce water through the outlet. Minimum of 50 gallons of water.

Signs of Effluent Line break or Leach Field failure: Yes  No  \*

Surfacing Water  Moist Soil  Backflow into Tank for Over 30 Minutes

Other  Explain. \_\_\_\_\_

Butte County Certified Professional

Phone Number

Name of Inspector

Signature

Date

\* This hydraulic test of the effluent line does not constitute a full hydraulic load test of the dispersal field. A full hydraulic load test can only be effectively done with more water and when the system has been in continual use.