



Butte County Department of Development Services
7 County Center Drive, Oroville, CA 95965
Main Phone: (530) 552-3700 Fax: (530)538-7785
www.buttecounty.net/dds

FORM NO

DPC-5

BUILDING DESIGN CRITERIA

CURRENT CODES:

2019 California Building Code (CBC)
2019 California Residential Code (CRC)
2019 California Electrical Code (CEC)
2019 California Mechanical Code (CMC)
2019 California Plumbing Code (CPC)
2019 California Energy Standards
2019 California Fire Code
2019 California Green Building Standards Code

Loading: ASCE 7-16

Wood: NDS-2018 and SDPWS-2015

Concrete: ACI 318-14

Masonry: TMS 402-2016 and TMS 602-2016

Structural Steel: AISC 360-16 and AISC 341-16

The 2019 California Codes are available for purchase from the International Code Council at www.iccsafe.org and may viewed online at <https://www.dgs.ca.gov/BSC/Codes>.

LIVE LOADS: per 2019 CBC Table 1607.1

WIND DESIGN:

Per ASCE 7-16 Chapters 26 - 31

Risk Category: (see 2019 CBC Table 1604.5)

- I Miscellaneous Occupancy
- II Standard Occupancy (not I, III, or IV)
- III High Occupancy
- IV Essential Facility, Hazardous Facility

Wind Speed: depends on risk category

87 mph (RC I), 95 mph (RC II), 102 mph (RC III), 105 mph (RC IV)

Wind Exposure Category: B or C depending on building height, terrain, and surface roughness:

Exposure B: Terrain with buildings, forest, etc. 20' or more in height covering at least 20% within 1 mile of the site.

Exposure C: Flat and generally open terrain within ½ mile or more from the site.

SEISMIC DESIGN:

Per Chapters 11 - 23 of ASCE 7-16

Seismic Design Category (SDC) can be determined from <https://seismicmaps.org/> and is dependent on earthquake ground motion, soil characteristics, and risk category.

FOUNDATION DESIGN VALUES - WITHOUT A SOILS REPORT:

Foundations shall be designed for Class 5 soil materials as specified in 2019 CBC Table 1806.2 unless a soils investigation report is provided by a registered design professional to substantiate higher design values.

Load-Bearing Values for Class 5 Material (2019 CBC Table 1806.2):

- Allowable Bearing Pressure = 1500 psf.
- Allowable Lateral Bearing (Passive) = 100 psf/ft.
- Allowable Cohesion = 130 psf times the contact area

The Building Official may require a soils report or geotechnical report in areas with steep slopes, disturbed soils, questionable soils, or areas known to contain highly expansive soils.

SNOW LOADS:

Minimum Ground Snow Loads for Structures not Manufactured Homes:

<u>Elevation (Feet)</u>	<u>Minimum Ground Snow Load</u>
0 - 1499	No Requirements
1500 - 1999	20 psf
2000 - 2499	37 psf
2500 - 2999	55 psf
3000 - 3499	75 psf
3500 - 3999	97 psf
4000 - 4499	122 psf
4500 - 4999	149 psf
5000 - 5499	180 psf
5500 - 6000	215 psf

Snow load values on this chart may be interpolated. Ground elevations can be determined from Google Earth or USGS topo maps.

Ground snow loads can be converted to roof snow load in accordance with ASCE 7-16 Chapter 7.

Residential structures proposed in areas where the ground snow loads exceed 70 psf require design by a Registered Design Professional (California Licensed Engineer or Architect) per CRC R301.2.3.

Minimum Roof Snow Loads for Manufactured Homes:

<u>Elevation (Feet)</u>	<u>Minimum Roof Snow Load</u>
0 - 2000	20 psf
2001 - 3000	30 psf
3001 - 4000	60 psf
4001 - 5000	80 psf
Over 5000	see snow load chart above

Approximate elevations for some Butte County locations:

Berry Creek	2200'	Feather Falls	3000'
Butte Meadows	4500'	Forbestown	2800'
Clipper Mills	3600'	Forest Ranch	2400'
Cohasset	3200'	Magalia	2400'
Concow	2200'	Stirling City	3600'
De Sabla	2720'	Yankee Hill	2200'

FLOOD ZONE:

To determine if a property is in a FEMA flood hazard zone click the following link:

<https://msc.fema.gov/portal/search#searchresultsanchor>

See Butte County Code Chapter 26 for construction requirements in FEMA designated flood hazard zones.

https://library.municode.com/ca/butte_county/codes/code_of_ordinances?nodeId=CH26BU_ARTIVF_LHAPR

A flood Elevation Certificate is required for new construction or substantial improvements to existing structures in the flood zone. Substantial Improvement is defined as 50% or more of the market value of the existing structure with depreciation of the existing structure taken into account. See <http://www.fema.gov/national-flood-insurance-program/definitions> for definitions.

Information about the National Flood Insurance Program can also be obtained from FEMA's website:

<http://www.fema.gov/national-flood-insurance-program>

SPECIAL INSPECTIONS:

Special Inspection is required in accordance with 2016 CRC R109.1.5.2 and CBC Chapter 17.

Special inspectors must be employed by the owner and approved by the Butte County Building Division. Special inspectors not already approved by the Butte County Building Division must submit a Statement of Qualifications and verification of current ICC (or equivalent) certification for the particular item they will be inspecting. A list of Butte County approved special inspectors can be found at the following link: https://www.buttecounty.net/Portals/10/Docs/DPC/DPC-20_Approved_Special_Inspectors_Contact_List.pdf

WILDLAND URBAN INTERFACE (WUI):

Building construction in the Wildland Urban Interface (WUI) area must be in accordance with 2019 CRC R337 or CBC Chapter 7A, *Materials and Construction Methods for Exterior Wildfire Exposure*. A list of approved building materials can be found at the following link:

<https://osfm.fire.ca.gov/divisions/fire-engineering-and-investigations/building-materials-listing/bml-search-building-materials-listing/>

ADDITIONAL INFORMATION:

Go to the Butte County Department of Development Service's website www.buttecounty.net/dds for additional information.

Click on Parcel Look-Up <http://www.buttecounty.net/dds/Planning/Documents/Parcel-Lookup-Tool> and enter an address, assessor's parcel number, or place to see available GIS layers and obtain specific parcel information.