



BUTTE COUNTY PUBLIC HEALTH DEPARTMENT DIVISION OF ENVIRONMENTAL HEALTH SWIMMING POOL OFFICIAL INSPECTION REPORT

SITE NAME Gridley Pool -CSA 34						DATE 8/23/16	
POOL ADDRESS 199 E. Hazel St., Gridley, CA 95948						REINSPECTION ON OR AFTER Summer 2017	
OWNER				PHONE		PR # PR0002637	
POOL TYPE	SPA TEMP	FREE CHLORINE	COMBINED CHLORINE	PH	CYANURIC ACID	INVENTORY TYPE	SERV CODE
Swimming Pool	-----	-----	-----	-----	-----	FLOW RATE	06
						150 gpm	

The marked items represent violations of Title 22 & 24, California Code of Regulations and must be corrected - See reverse side for the code sections and general requirements that correspond to each violation listed below

In = In Compliance OUT = Out of Compliance N/A = Not Applicable											
IN	OUT	N/A	SAFETY EQUIPMENT	IN	OUT	N/A	POOL AND POOL AREA	IN	OUT	N/A	RECIRCULATION EQUIPMENT
			1. Life ring & rope				22. Dirty water line tiles				48. Filter requires backwash
			2. Body hook				23. Broken/missing tiles				49. Broken/missing pressure gauge(s)
			3. Lifeguard sign				24. Broken/missing depth markers				50. Broken/missing flow meter
			4. Artificial Respiration & CPR sign				25. Broken/missing coping				51. Chlorinator missing - not operational
			5. 911 Sign, Pool name & address		X		26. Inadequate skimming				52. Chlorinator filled & operational
			6. Maximum occupancy sign				27. Water level too low/high				53. Direct connection to sanitary sewer
			7. Spa Warning sign				28. Broken/missing skimmer basket				54. Direct connection to water supply
			8. No diving sign				29. Broken/missing skimmer weir				55. Secure/dirty equipment room
			9. Spa ER shut-off switch sign				30. Broken/missing diverter valve				56. Gas chlorination system
			10. Keep Closed sign				31. Spa pool water > 104°F				57. Spa ER shut-off switch
			11. Diarrhea sign				32. Animal in pool/pool area				58. Label pipes/valves
			12. Spray ground sign				33. Chlorine tablets in skimmer				ANCILLARY AREAS
			13. Signs/equipment visible				34. Pool cover/Pool sweep				59. Inoperable drinking fountain
			WATER QUALITY				35. Broken/missing main/skimmer equalizer cover(s)				60. Unsanitary restroom/shower area
			14. Low/high chlorine				36. Broken/loose/missing stair handrail				61. Hot water in shower/restroom
			15. Low/high chlorine with Cyanuric Acid		X		37. Broken/loose/missing ladder grab rail				62. No soap in shower
			16. pH out of range				38. Underwater light not operational				63. Soap/paper towel/toilet paper in restroom
			17. Cyanuric Acid > 100 ppm				39. Night time operation of pool light				OPERATOR
			18. No DPD Test Kit				40. Deck obstruction				64. No responsible supervision of pool
			19. Cloudy water				41. Trip hazard on pool deck				65. Pool/equipment area not accessible
	X		20. Pool shell in disrepair				42. Fence in disrepair				66. No daily/monthly logs
			21. Dirt/leaves/algae/debris				43. Self-closing/latching gate in disrepair				67. No lifeguard service or certification
							RECIRCULATION EQUIPMENT				68. Operating License/Plan Check
					X		44. Turn Over Rate not met				69. Other
							45. Recirculation system				70. POOL CLOSED BY EH
							46. Pump not operational/SVRS				
							47. Filter not operational				

OBSERVATIONS AND CORRECTIVE ACTIONS: **Structural Inspection Only.**
See Page 2.

Reinspection fees will be charged for all subsequent reinspections unless an acceptable corrective time schedule has been submitted and approved by this Department. If, for any reasons beyond your control, you cannot correct the indicated violations by the next scheduled time, call this office prior to the inspection day.

202 Mira Loma Drive
Oroville, CA 95965
(530) 538-7281 or (530) 891-2727
FAX (530) 538-5339
www.buttecounty.net/publichealth/

R.E.H.S. Jennifer Veilleaux

RECEIVED BY:

1. Provide a minimum 17 inch (exterior diameter) life ring with attached rope that is of sufficient length to span the maximum width of the pool. The life ring must be readily accessible.
2. Provide a body hook permanently attached to a fixed length pole at least 12 ft. in length. The rescue pole must be readily accessible.
3. Post a legible sign stating "WARNING: NO LIFEGUARD ON DUTY" in letters at least 4" high. In addition, the sign shall state "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance".
4. Post a sign with an illustrated diagram with text at least ¼ inch high of artificial respiration and CPR procedures.
5. Post a legible emergency telephone number (911) sign with the number of the nearest emergency services, and the name and street address of the pool facility.
6. Post a legible sign stating the maximum pool user capacity in letters at least 4" high. The maximum occupant capacity for a swimming pool shall be one pool user for every 20 sq. ft. of pool surface area, and for a spa pool, one pool user for every 10 sq. ft. of spa surface area.
7. Post a legible spa precaution sign stating the following language in at least 1" letters:

CAUTION

 - Elderly persons, pregnant women, infants and those with health conditions requiring medical care should consult with a physician before entering the spa.
 - Unsupervised use by children under the age of 14 is prohibited.
 - Hot water immersion while under the influence of alcohol, narcotics, drugs or medicines may lead to serious consequences and is not recommended.
 - Do not use alone.
 - Long exposure may result in hyperthermia, nausea, dizziness or fainting.
8. Post a legible "NO DIVING" sign in 4" letters at pools with a maximum water depth of 6 feet or less.
9. Spa emergency shut-off switch shall be labeled with sign in 1" letters stating "EMERGENCY SHUT-OFF SWITCH".
10. Post a sign on exterior side of all gates and doors leading into pool enclosure area stating "KEEP CLOSED" in 4" letters.
11. A sign in letters at least 1" high shall be posted at the entrance area of a pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed in the pool.
12. Post a sign at each spray ground that states "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK" in 4" letters.
13. All required signs and rescue equipment must be clearly visible from the pool deck.
14. For swimming pools, maintain a free chlorine residual of at least 1.0 ppm. For spa pools/wading pools/spray grounds, maintain a free chlorine residual of at least 3.0 ppm. Maximum free chlorine level is 10 ppm. Maintain combined chlorine level at 0.4 ppm or less.
15. For swimming pools, maintain a free chlorine residual of at least 2.0 ppm when cyanuric acid is used. Maximum free chlorine level is 10 ppm.
16. Maintain the pH between 7.2 and 7.8.
17. Maintain the level of cyanuric acid at or below 100 ppm.
18. Provide an approved DPD type pool test kit which will measure total and free chlorine residual.
19. Eliminate cloudiness and maintain pool water in a clean and clear condition.
20. Maintain pool shell in good repair.
21. Eliminate dirt/leaves/debris/algae from the pool.
22. Clean the water line tiles.
23. Replace broken/missing pool tiles.
24. Replace broken/missing/unreadable/misleading depth marker tiles and deck depth markers.
25. Replace damaged or missing coping tile and/or coping seal.
26. Provide proper/adequate skimming action in the pool.
27. Raise/lower water level to the mid-point of the skimmer opening.
28. Replace broken/missing skimmer strainer basket.
29. Replace broken/missing skimmer weir assembly.
30. Replace broken/missing skimmer air lock protective device.
31. Limit spa pool water temperature to a maximum of 104°F.
32. Animals are prohibited in the pool and pool area.
33. Remove and discontinue placing chlorine tablets in the pool skimmer(s).
34. Pool covers and pool sweeps shall be completely removed from pool/spa and stored at least 4' from pool/spa whenever the pool/spa is available for use.
35. Secure or replace missing/broken main drain / skimmer equalizer suction outlet cover(s) with an approved anti-entrapment type.
36. Secure/repair/replace loose stair handrail(s).
37. Secure/repair/replace ladder/ladder step treads/grab rails.
38. Provide/repair or replace underwater light(s).
39. Maintain underwater pool light(s) "on" during all times the pool is open for use after dark. If the pool is not separately enclosed, maintain pool light(s) on during the entire night time hours.
40. Eliminate deck obstructions so as to provide an unobstructed deck area at least 4' out from and all around pool (around at least 50% of a spa).
41. Eliminate trip and fall hazard of deteriorating/uplifting deck in pool area.
42. Repair the pool fence/enclosure.
43. Provide/maintain a self-closing gate/door to pool area with self-latching hardware between 42" to 44" above finished grade.
44. Provide a minimum turnover rate as follows: [Swimming pools – 6 hours] [swimming pools built before October 1982 – 8 hours], [spa pools & spray ground – 1/2 hour], [wading pools – 1 hour]. Required min. flow rate - #gallons in pool/rec turnover x 65%.
45. Operate the pool recirculation system at all times the pool is open for use or longer as necessary to maintain the water clean and clear.
46. Repair/replace the recirculation pump. Repair/replace the safety vacuum release system or suction-limiting vent system required on each pool with a single main drain (pool with unblockable drain is exempt).
47. Repair/replace the filter.
48. Backwash/clean the filter.
49. Provide/repair/replace the pressure/vacuum gauge(s) for each pump system.
50. Provide/repair/replace the flow meter for each recirculation system.
51. Provide/repair/replace the automatic chlorinator / brominator.
52. Maintain the automatic chlorinator / brominator filled and operational.
53. There shall be no direct connection of the pool or its recirculation system with a sanitary sewer or drainage system. Provide air-gap separation of 2 X diameter of discharge pipe.
54. There shall be no direct connection of the pool or its recirculation system with the domestic water supply. Provide an approved backflow prevention device on the fill line to the pool, and on all hose bibs within 75 feet of pool.
55. Clean the pool equipment room/area.
56. Correct specified items relating to the gas chlorination system.
57. Spa emergency shut-off switch shall shut off all spa pumps.
58. Label all valves/pipes in pool equipment area with their purpose and direction of flow. If more than one pool on-site, label equipment as to which system it serves.
59. Repair/replace inoperable drinking fountain.
60. Maintain restrooms, showers, dressing rooms, and related fixtures clean and in good repair.
61. Showers and lavatories shall be provided with hot and cold water. A means to limit the hot to a maximum of 110°F shall be provided.
62. Provide soap in soap dispensers or containers in showers.
63. Provide soap in permanently installed soap dispensers, paper towels or hot air blowers, and toilet tissue at toilet facilities.
64. Every pool shall be under the supervision of a person who shall assume responsibility for compliance with all requirements relating to pool operation, maintenance and safety of bathers. Post routine operating procedures in a readily accessible location.
65. The pool(s) were not accessible or only partially accessible for inspection. Please contact the inspector to make arrangements for a complete inspection of the pool and pool area.
66. Maintain a daily log of disinfection residual, pH, and pool maintenance. Test and record cyanuric acid (if used) monthly (more often if needed for spas). Test and record combined chlorine at a frequency required to maintain at or below 0.4 ppm.
67. Provide lifeguard service. Lifeguards must possess qualification as required by the State Department of a Health Services.
68. No public pool shall be operated without a valid operating license from this Department. Submit plans to this Department for approval prior to remodeling pool/pool area, or replacing pool equipment.
69. Other.
70. Pool closed by Environmental Health. Do not re-open without written EH permission.