



<b>DBA/NAME</b> Cal Java #4	<b>DATE</b> 10/22/09
<b>Page 2 of 2</b> 1835 Mangrove Avenue, Chico, CA 95926	2796

**OBSERVATIONS AND CORRECTIVE ACTIONS**

- 1- No food safety certificate. Provide documentation within sixty days that at least one person currently working at this facility has passed an approved food safety certification examination. Fax or mail to this Department. Please include name of facility on certificate.
- 6- Observed dish detergent in use at hand sink. Provide hand soap so as to encourage employee hand washing.  
Note: Detergent at hand sink in squeeze bottle. Soap at hand sink shall be provided in sanitary dispenser.
- 14- Food handler reports utensils are washed/rinsed/sanitized and then rinsed. Do not rinse utensils after sanitizing.
- 32- No labels/ingredient lists available for individually wrapped pastries. Provide.
- 33- Observed worn laminate on counters and missing laminate on cabinet door by utensil sink. Repair where needed to be smooth and easily cleanable.
- 35- Observed leak under ice machine. Repair.
- 35, 41- Observed end of drainage hose for ice bin in bottom of floor sink. Cut hose or secure to provide required air gap.
- 36- Observed clean wiping rags stored in cabinet in restroom. Do not store food or food related items (beverage cups, wiping rags, utensils, etc.) in restroom so as to prevent accidental contamination.  
Note: Wiping relocated to storage room during inspection.
- 38- Observed lights over utensil sink to be nonoperational. Replace bulbs or repair.
- 41- Observed leak at utensil sink faucet and drainpipe. Repair.