

## SPCC Plan Options and Requirements

<b>Qualified Facilities</b>		<b>Non- Qualified Facilities</b>
<p>10,000 gallons or less aggregate aboveground oil storage capacity; <b>and</b></p> <p>Has had <b>no</b> single discharge to navigable waters or adjoining shorelines exceeding 1,000 gallons and <b>no</b> two discharges each exceeding 42 gallons within any 12 month period in the prior 3 years.</p>		<p>Greater than 10,000 gallons aggregate <b>or</b></p> <p>A qualified facility which <b>has</b> had a single discharge to navigable waters or adjoining shorelines exceeding 1,000 gallons and/or has had two discharges each exceeding 42 gallons within a 12 month period in the 3 years prior.</p>
<b>Tier I</b>	<b>Tier II</b>	
All individual aboveground oil container <b>are less than 5,000 gallons</b>	Has individual aboveground oil container <b>greater than 5,000 gallons</b>	
<p>Complete a self certified SPCC Plan. The US EPA SPCC template may be used (Appendix G of 40 CFR part 112).</p> <p>A Qualified Tier I Facility may also prepare a Tier II Plan or complete SPCC Plan.</p>	<p>Complete a self certified SPCC Plan in accordance with applicable requirements of 40 CFR Section 112 and subparts B of the rule. The CUPA Forum Board Tier II Template may be used.</p> <p>A Qualified Tier II Facility may also prepare a complete SPCC Plan.</p>	<p>Complete a SPCC Plan that is reviewed and certified by a Professional Engineer in accordance with all applicable requirements of 40 CFR Section 112.7 and subpart B and/or Subpart C of the rule.</p>
<p>Deviations from certain plan requirements not allowed. Impracticability for secondary containment not allowed.</p>	<p>Deviations from certain plan requirements listed in 40 CFR §112.7(a)(2) and Impracticability for secondary containment (40 CFR §112.6(b)(3)(ii)) <b>allowed if reviewed and certified, in writing, by a licensed Professional Engineer</b></p>	<p>Deviations from certain plan requirements listed in 40 CFR §112.7(a)(2) and Impracticability for secondary containment (40 CFR §112.6(b)(3)(ii)) <b>allowed .</b></p>